

Type sheet Deflagration and endurance burning proof ventilation hood KITO[®] BEH-6-...-IIB3-K



Application

As an end-of-line flame arrester to protect vent openings of storage tanks. Explosion and endurance burning proof for all inflammable liquids and vapors of explosion group IIB3 with a maximum experimental safe gap (MESG) ≥ 0.65 mm and an maximum operating temperature of 60 °C. This device is not permitted to be installed in enclosed areas. Installation on top of storage tanks, tank access covers or breather pipelines. The flame arrester protects a tank against flashbacks but allows the flow of gases out into the atmosphere and air into the tank.

Dimensions (mm)





DN		D	u	ka
DIN	ASME	D	п	ĸġ
80 PN 16	-	353	250	
100 PN 16	-			

Weight refers to the standard design

Example for order

KITO[®] BEH-6-80-IIB3-K

(design with flange connection DN 80 PN 16)

Type examination certificate to EN ISO 16852 and CE-marking in accordance to ATEX-Directive 2014/34/EU

KITO Armaturen GmbH) +49 (0) 531 23000-0

> +49 (0) 531 23000-10

Grotrian-Steinweg-Str. 1c D-38112 Braunschweig www.kito.de

VAT Reg.No DE812887561 info@kito.de \bowtie

B 4.1 N 05-2018 Date: Created: Abt. Doku KITO Design subject to change

page 1 of 2



Type sheet Deflagration and endurance burning proof ventilation hood **KITO[®] BEH-6-...-IIB3-K**



Design

	standard	optionally
housing	cast steel 1.0619	stainless cast steel 1.4408
KITO [®] -flame arrester element	completely interchangeable	
KITO [®] -casing / KITO [®] -grid	stainless steel mat. no. 1.4308 / 1.4310	stainless steel mat. no. 1.4408 / 1.4571
weather hood	steel, hood can fold automatically as a result of folding mechanism and fusing element	stainless steel mat. no. 1.4571, hood can fold automatically as a result of folding mechanism and fusing element
connection	flange EN 1092-1 type B1	

performance curves

Flow capacity V based on air of a density $\rho = 1.29 \text{ kg/m}^3$ at T = 273 K and atmospheric pressure p = 1.013 mbar. For other gases the flow can be approximately calculated by

$$\dot{\mathbf{V}} = \dot{\mathbf{V}}_{\mathrm{b}} \cdot \sqrt{\frac{\rho_{\mathrm{b}}}{1.29}} \ or \qquad \dot{\mathbf{V}}_{\mathrm{b}} = \dot{\mathbf{V}} \cdot \sqrt{\frac{1.29}{\rho_{\mathrm{b}}}}$$



page 2 of 2

KITO Armaturen GmbH Grotrian-Steinweg-Str. 1c

D-38112 Braunschweig VAT Reg.No DE812887561

≞ www.kito.de

+49 (0) 531 23000-0

+49 (0) 531 23000-10

 \bowtie info@kito.de

)

B 4.1 N Date: 05-2018 Created: Abt. Doku KITO Design subject to change