# Quick Start Guide

## 1200-RRRO-00-0-x Programmable PID Controller







Heat - Cool - Alarm

#### **GETTING STARTED**

- Unpack Contents
- Verify model numberand application
- Power Controller
- Program for vourapplication

#### Note

Change all menu parameters by using the front panel buttons





### What's Included






- 48x96 DIN 1200-BBB0-00-0-x Gefran Controller x2
- Mounting Bracket
- Panel Sealing Gasket
- Screw Terminal Cover
- Multi-Language Manual

## Program Your Gefran Controller

- Press and hold (a) until PRS appears ENTER 99
- Press once. Pro appears ENTER 128
- Press 🕞 once, PRS appears ENTER 99
- Press and hold (a) until Hrd appears
- Press ( twice, Ltr appears ENTER 14
- Press (a) twice, but appears ENTER !
- Press and hold ( until [F5] appears
- Press and hold **(F)** until **(In)** appears
  - ENTER G cooling with Air
  - ENTER / cooling with Oil
  - ENTER  $\mathcal{G}$  cooling with Water
- Press and hold ( until InPappears
- Press **(F)** twice, £50 appears ENTER the Input Sensor number from the list
- Press F repeatedly until Lo.5\* appears ENTER the minimum Input Scale limit
- Press once, H : 5\* appears ENTER the maximum Input Scale limit
- Press Prepeatedly until La.L\* appears ENTER the minimum Alarm Scale limit
- Press once, H.L. appears ENTER the maximum Alarm Scale limit
- Press and hold (F) until [Jut appears
- Press **(a)** three times, rt. I appears ENTER I
- Press and hold (a) until you return to the main process display. This is the display after PR5 and will be indicated by the Process Variable if an input sensor is connected, or La, Hi, 5br, Err if no input is connected.
- Use the \( \Delta \) and \( \nabla \) buttons to adjust the control setpoint (SV) from the main display.
- Press  $\bigcirc$  once from the main display,  $\beta L$ . Jappears to adjust the Alarm 1 setpoint.
- Press the O button to switch between automatic and manual control modes from the main display. LED 1(L1) will light while in manual mode.
- \* Parameter may be left at default value for input types 0...37

## 3 Connect Your Controller

Additional wiring configurations are available in the User's Manual and General Setup Guide







Input Sensor

1 TCJ°F

2 TCK°C

3 TCK°F

4 TCR°C

5 TCR°F

6 TCS°C

7 TCS°F

8 TCT°C

9 TCT°F

30 PT100 °C

31 PT100 °F

32 JPT100 °C

33 JPT100 °F

34 PTC °C


35 PTC °F

36 NTC °C

37 NTC °F


44 4...20 mA

46 O...10 V









#### If needed, automatic tuning (Self-Tune) can be enabled with the following steps

With the machine at ambient temperature and the control setpoint (SV) set...

- Press and hold (F) until [F] appears
- Press once, 5. Tu appears ENTER 2
- Press 🖨 once
- Cycle power to the controller
- LED 3 [L3] will flash during the tuning process

Self-Tune will automatically save new PID values once complete

This Quick Start Guide provides basic information on setting up the Gefran 1200 controller for the application referenced above. Additional software and hardware configuration information can be found in the User's Manual included with this controller or online at www.gefran.com



